

**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**

ISO-7637-2:2004 & OEM EQUIVALENT PULSE

1. PURPOSE

- 1.1. To provide specific test method setup configuration instructions in full compliance with OEM specifications and international standards.

2. SCOPE

- 2.1. To establish consistency and repeatability in test method results using the equipment and technical resources available in EMC laboratory inventory.

3. RESPONSABILITY

- 3.1. EMC laboratory authorized personnel.
See **201709 EMC LAB TEST EQUIPMENT COMPETENCY MATRIX** and **201705 EMC LAB COMPETENCY MATRIX**.

4. EQUIPMENT & MATERIALS

- 4.1. All test equipment that requires calibration shall be within its calibration period and shall be traceable to A2LA certified labs. EMC lab personnel must ensure that certificates of calibration are obtained when equipment is sent out for calibration or repair. (See *REFERENCES* section in document for equipment specific internal procedures and records).
- 4.2. **Power supply**
 * R_i of less than 0,01 Ω d.c.
 * $Z_i = R_i$ for frequencies less than 400 Hz.
 * output deviation ≤ 1 V from 0 to maximum load (including inrush current) and shall recover 63% of its maximum excursion within 100 μ s.
 * superimposed ripple voltage $U_r \leq 0,2$ V peak-to-peak and shall have a minimum frequency of 400 Hz.
 * simulates the low internal impedance of the battery
 * battery voltages 13,5 V and 27 V, respectively.
- 4.3. **Oscilloscope:**
 * digitizing oscilloscope (single sweep sampling rate ≥ 2 GHz/s, bandwidth 400 MHz, input sensitivity: at least 5 mV/div.)
 * analog storage oscilloscope may be used if:
 - bandwidth d.c. to at least 400 MHz;
 - writing speed of at least 100 cm/ μ s;
 - input sensitivity of at least 5 mV/division.
- 4.4. **Voltage probe:**
 * attenuation of 100/1,
 * maximum input voltage of at least 1 kV,
 * input impedance Z and capacitance C according to Table 2 ;
 * maximum probe cable length of 3 m;
 * maximum probe ground length of 0,13 m.
- | f[MHz] | z[k Ω] | C[pF] |
|--------|----------------|-------|
| 1 | >40 | <4 |
| 10 | >4 | <4 |
| 100 | >0.4 | <4 |
- 4.5. **Test pulse generator:**
 * peak voltage U_s tolerance of +10% / -0%
 * timing (t) tolerance of $\pm 20\%$
 * internal resistance (R_i) tolerance of $\pm 20\%$

**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**


Fig.4-1



ISO Pulse 1 (12V)	
Rise time t_r (10 - 90%)	$1\mu s + 0\% // - 50\%$
Pulse duration t_d (10 - 10%)	$2ms \pm 10\%$
Internal resistor	$10\Omega \pm 10\%$
ISO Pulse 1 (24V)	
Rise time t_r (10 - 90%)	$3\mu s + 0\% // - 50\%$
Pulse duration t_d (10 - 10%)	$1ms \pm 10\%$
Internal resistor	$50\Omega \pm 10\%$
Trigger	
Automatic	Automatic release of the pulses
Repetition rate	0.2s – 99.0s
Manual	Manual release of a single pulse
External	External release of a single pulse
Battery supply switch	Selectable Off time, $t_o = 0 - 10.000ms$
Output	
+/- output	Safety laboratory plugs
Coupling	To the battery +line
Decoupling	Via diode and battery supply switch
DUT supply	max. 60V / 25A

Tbl.4-1

Idx	Equipment Description	Model	Maker	INV#
1.	Coupling Network	CNA200B2	EMTEST	2167
2.	Pulse #1 & #2a Micropulse Generator	MPG200B	EMTEST	2162
3.	Power Supply	VDS200B2	EMTEST	2171
4.	Oscilloscope	TDS784A	TEKTRONIX	2161
5.	Voltage probe	CNA200B2	TEKTRONIX	2167
6.	ISMISO software	Rev 4.24	EMTEST	2176

	FLEXTRONICS LABORATORY MANAGEMENT SYSTEM	DOC #	705304-111
		REVISION #	B
		SUPERSEDE	A
		RELEASE DATE	2010-04-16
EMC LABORATORY 213 Harry Walker Parkway South NEWMARKET, ON, L3Y 8T3 Tel: 905-952-1242	IMMUNITY TO TRANSIENTS ON POWER LINES PULSE #1 TEST PROCEDURE	DOC TYPE	WORK INSTR

5. SUMMARY OF TEST METHOD

- 5.1. Evaluates DUT's immunity from conducted transients on power and control circuits connected directly to the vehicle's battery or indirectly by a switch or load (e.g. pull-up resistor).
- 5.2. The switching of inductive loads connected to the battery supply of vehicles creates both positive and negative pulses which electronics connected to the battery supply must be able to withstand.

6. SAFETY PRECAUTIONS

- 6.1. Only EMC laboratory personnel mentioned in 201709 EMC LAB TEST EQUIPMENT COMPETENCY MATRIX is allowed to handle the EMTEST equipment.

7. TEST PLAN

- 7.1. For FlexAutomotive products the EMC test plan is generated using LMS004 and OEM template. The OEM specific EMC test plan template is downloadable from EMCLAB subfolder under DOCUMENT CONTROL network shared folder.
- 7.2. The test plan should indicate:
 - 1) DUT, harness, I/O loads configuration and position relative to ground plane.
 - 2) DUT activation and monitoring method, expected FPSC, and pass/fail criteria.
- 7.3. In the absence of an EMC test plan use information provided by the test requester in 201696 INTERNAL TEST REQUEST FORM. This approach is applicable for "engineering development" testing.

8. RECORDS

- 8.1. **Test reports** including plots and data files are saved over over the LAN in a dedicated folder:
\\nmknt062\apps\le-ecn\emclab\result\project#\job#\test group
 Example of grouping test results per job#: CTI, CTE, RE, CE, BCI, ESD, TP, PT, TRENDS.
- 8.2. In a similar manner the EMC **test plans** (TP), **proficiency testing** (PT), **trends** are stored under a **project#\job#** folder.
- 8.3. The intranet application EMC LAB SCHEDULER database is used to maintain and provide fast access to testing related records. The application is available via this link: <http://nmknt063/emclab/labscheduler/>


**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**

9. TEST SETUP

9.1. Prior to start testing all samples must be labeled per 900712 EMC LAB LABELS.

9.2. A default list of required equipment is pull-out at the time the test method is selected (721179 EMC LAB, TEST REPORTS DATABASE).

Fig.9-1



**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**

10. ISO-7637-2:2004 PULSE#1

- 10.1. This test is a simulation of transients due to supply disconnection from inductive loads. It is applicable to DUTs which, as used in the vehicle, remain connected directly in parallel with an inductive load (see ISO-7637-2:2004 Annex F).
- 10.2. ISO-7637-2 does not mention for pulse#1 to place the DUT and/or harness on an insulator 5 cm above the ground plane.

Fig.10-1




Table 3 — Parameters for test pulse 1

Parameter	12 V system	24 V system
U_s	-75 V to - 100 V	- 450 V to - 600 V
R_i	10 Ω	50 Ω
t_d	2 ms	1 ms
t_r	$1_{-05}^0 \mu s$	$3_{-1,5}^0 \mu s$
t_1^a	0,5 s to 5 s	
t_2	200 ms	
t_3^b	< 100 μs	

^a t_1 shall be chosen such that the DUT is correctly initialized before the application of the next pulse.

^b t_3 is the smallest possible time necessary between the disconnection of the supply source and the application of the pulse.

**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**

11. DC10614:2005 PULSE#1

- 11.1. Pulses are applied individually to each battery and ignition line and any inputs or outputs supplied from battery or ignition voltage. Check DUT for inadvertent turn-on, no damage, no lockups requiring power off reset, and no effect on stored data or false diagnostic indication.
- 11.2. Pulses #1 and #2 applied for 1 hour each (applications: 720 for pulse #1, 7200 for pulse #2).
Pulses #3a and #3b applied for one half hour each (1,800,000 applications each).

Fig.11-1

**Table 30: Supply Voltage Transients DC-10614
- Immunity Requirements**

Transient Pulse	Performance Status Group A	Performance Status Groups B, C and D
Pulse #1	II	II

Table 31: Test Pulse 1 - Parameters

Parameters	12 V System	24 V System	42 V System
U_p in V	13.5	27	42
U_t in V	-100	-300	-100
t_r in μ s	1	1	1
t_d in ms	2	2	2
t_1 in s	5	5	5
t_2 in ms	200	200	200
t_3 in μ s	≤ 100	≤ 100	≤ 100
R_L in ohms	10	10	10
Test duration in h	1	1	1

**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**

12. DC11224:2007 PULSE#1

- 12.1. In addition to ISO-7637-2 DC11224 requires pulse#1b, shows specific connections for electrically asymmetrical and electrically symmetrical devices, and mention that lines between the DUT and the test pulse generator must be routed at a height of 50 mm above the ground plane and shall be 500 mm in length.

Fig.12-1





Figure 19: Test Setup for Devices with Two Voltage Supply Connections



b) DUT with Symmetrical Connection

Figure 20: Connection of the DUT

DC-11224

**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**
13. CS-11809:2009 PULSE#1

- 13.1. In addition to ISO-7637-2 transient immunity pulses Chrysler requires Pulse#1b, specifies that test pulses are applied individually to all DUT battery, ignition, accessory and appropriate I/O lines and mention that lines between the DUT and the test pulse generator wires must be routed at a height of 50 mm above the ground plane and shall be less than or equal to 500 mm in length.
- 13.2. Note the change from DC-11224: **Level 1** (non-critical functions) and **Level 2** (critical functions).

Fig.13-1

TABLE 20: TRANSIENT CONDUCTED IMMUNITY ON SUPPLY LINE LIMITS					
Pulse No.	Test Voltage U_s [V]		Level 1 Status	Level 2 Status	Test Duration (min)
	12 V	24V			
1	-100	-600	II	II ¹⁾	10
1b	30	50	I	I	10
2a	100	150	I	I	10
3a	-150	-200	I	I	10
3b	100	200	I	I	10

NOTE 1: Powertrain controllers shall return to normal operation after the disturbance is removed. A reset upon application of one key cycle is not allowed.




TABLE 21: PARAMETERS OF TEST PULSE 1b		
Parameters	12 V System	24 V System
U_A [V]	13.5	27
U_s [V]	30	50
t_r [μ s]	1	1
t_d [ms]	2	2
t_1 [s]	5	5
R_i [Ω]	10	10

**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**

14. CS-11979:2010 PULSE#A

14.1. Note that CS-11979:2010 6.4.1 Transient Immunity of Supply Lines changes the pulse title (number).

Fig.14-1

CS-11979, Change A, 2010-04-13

TABLE 26: TRANSIENT IMMUNITY PULSE REQUIREMENTS						
#	Reference	Internal generator resistance Ri	Amplitude Vs (Us)	Pulse parameter	MINIMUM Number of pulses (MINIMUM test time)	Permitted behavior
A	Pulse 1 : generated at key-off with inductive loads present (ISO 1)	10 Ω	-100 V	td=2 ms	500 pulses	M1 ⁽¹⁾
A1	Pulse 1b : generated at key-off with inductances in series with loads or electrical motors running	10 Ω	+43.5 V	td=2 ms tr=0.001ms t1=5s	500 pulses	M1
B	Pulse 2 : generated at key-off with inductances in series with loads or electrical motors running (ISO 2a)	2 Ω	+100 V	td=0,05 ms	500 pulses	M1
C	Pulse 3a : generated by bounces and/or arcs at activation of switches or relays (ISO 3a)	50 Ω	-150 V	tr=5 ns td=100 ns t1=0,1 ms t4=10ms t5=100ms	15 min	M1
D	Pulse 3b : generated by bounces and/or arcs at activation of switches or relays (ISO 3b)	50 Ω	+100 V	tr=5 ns td= 100 ns t1=0,1 ms t4=10ms t5=100ms	15 min	M1
E	Pulse 5b : generated by a disconnected battery terminal while current is supplied from generator to battery (load-dump) (ISO 5b)	1 Ω	+ 40 V ⁽²⁾	td=400 ms	15 pulses	M1, M2 ⁽³⁾
NOTE 1: Operation M3 permissible during negative portion of pulse.						
NOTE 2: Test shall be carried out with a suppressor at Load Dump generator output clamping the pulse (Us=70V according Figure 11 of ISO 7637-2:2004) to +40V peak (ISO 5b).						
NOTE 3: Where required, M1 operating mode to be ensured.						

NOTE: The test duration in Table 26 is the minimum for testing against damage.
It is responsibility of the supplier to test thoroughly against functional sensitivity to these types of disturbances.

**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**
15. EMC-CS-2009:2010 PULSE #E

- 15.1. FORD Pulse "E" represents the voltage transient produced during switching of a higher current (> 5 ampere) inductive load that shares the same circuit with the DUT. The test pulse is equivalent to Test Pulse 1 delineated in ISO 7637-2. Pulse E is similar to Pulse A-1 except that it occurs when higher current loads (> 5 amperes) share the same circuit as the inductive load. The pulse can also occur on circuits with high capacitive loads (> 2uf)


Fig.15-1

EMC-CS-2009.1 Figure D-6: CI 220 Pulse E Characteristics
Pulse E - Parameters

U_p	13.5 V
U_s	-100 V
t_r	1 us
t_d	2 ms
t_1	5 s
t_2	200 ms
t_3	≤ 100 us
R_i	10 ohms

Waveform voltage begins and ends at U_p


Parameters listed are for open circuit conditions.



**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**

16. REPORT

- 16.1. Report pulse parameters, severity level, and DUT FPSC response. Include pulse verification waveform (no load, $U_A = 13.5 \pm 0.5$ V) acquired prior to test and test setup pictures, order of injection for each of the waveform amplitudes, number (repetitions) of the pulse applied, pulse period (interval between pulses), any deviation from a standard pulse waveform, point of application of pulse (pin number, letter, or name), exact characteristics of any disturbance during injection of the pulse.



Tbl.16-1

Parameter	12V system	Tolerance
1. U_s	-75.6V	+/- 10%
2. R_i	10 Ω	
3. t_d	2 ms	+/- 400 us
4. t_r	1 us	1 (+0/-0.5) us
5. t_1	0.5 s	0.5 s to 5s
6. t_2	200 ms	
7. t_3	< 100 us	

**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE****17. PROFICIENCY TESTING**

17.1. Follow instructions and scheduler provided in LMS011 EMC LAB PROFICIENCY TESTING PROGRAM and ISO-7637-2:2004 Annex-D (Test pulse generator verification procedure).

17.2. $U_A = 0V$.

Tbl.17-1

	Pulse Verification	U_s	t_r	t_d
1.	Pulse #1 No load (12 V system)	$-100 V \pm 10 V$	1 (+0/- 0.5) μs	$2\,000 \mu s \pm 400 \mu s$
2.	Pulse #1 10 Ω load (12 V system)	$-50 V \pm 10 V$	-	$1\,500 \mu s \pm 300 \mu s$
3.	Pulse #1 No load (24 V system)	$-600 V \pm 60 V$	3 (+0/- 1.5) μs	$1\,000 \mu s \pm 200 \mu s$
4.	Pulse #1 50 Ω load (24 V system)	$-300 V \pm 30 V$	-	$1\,000 \mu s \pm 200 \mu s$

18. TRENDS

18.1. Follow instruction provided in 721179 EMC LAB, TEST REPORTS DATABASE and 721186 EMC LAB, TRENDS AND STATISTICS. Perform trends on t_d and t_r .

19. DEFINITIONS

19.1. Use definitions per ISO 7637-1.

19.2. FPSC = Function Performance Status Classification


**IMMUNITY TO TRANSIENTS ON POWER LINES
PULSE #1 TEST PROCEDURE**

REFERENCES

LMS007			EMC LAB, EQUIPMENT CONTROL
LMS011			EMC LAB, PROFICIENCY TESTING PROGRAM
201707			EMC LAB, APPROVED EQUIPMENT SUPPLERS LIST
201711			EMC LAB, EQUIPMENT INVENTORY
201728			EMC LAB, APPROVED CALIBRATION SUPPLIERS LIST
201709			EMC LAB, TEST EQUIPMENT COMPETENCY MATRIX
201705			EMC LAB, COMPETENCY MATRIX
201696			INTERNAL TEST REQUEST FORM
900712			EMC LAB LABELS
721179			EMC LAB, TEST REPORTS DATABASE
721186			EMC LAB, TRENDS AND STATISTICS
201724			CALIBRATION SUPPLIER EVALUATION FORM
ISO 7637-1	2-nd Ed	Mar 15, 2002	Road vehicles - Electrical disturbances from conduction and coupling - Part 1: Definitions and general considerations
ISO 7637-2	2-nd Ed	Jun 15, 2004	Road vehicles — Electrical disturbances from conduction and coupling — Part 2: Electrical transient conduction along supply lines only
DC-10614	B	Dec 1, 2005	EMC Performance Requirements --- Components
DC-11224	A	Jun 1, 2007	EMC Performance Requirements --- Components
CS-11809	A	May 29, 2009	ELECTRICAL AND EMC PERFORMANCE REQUIREMENTS - E/E COMPONENTS
CS-11979	A	Apr 13, 2010	CHRYSLER/FIATELECTRICAL AND EMC PERFORMANCE REQUIREMENTS - E/E COMPONENTS
ES-XW7T-1A278-AC & corrections	AC	Oct 10, 2003	Component and Subsystem Electromagnetic Compatibility, Worldwide Requirements and Test Procedures
EMC-CS-2009.1	1	Feb 11, 2010	Electromagnetic Compatibility Specification For Electrical/Electronic Components and Subsystems
SAE J1113-11		Jun, 2007	Immunity to Conducted Transients on Power Leads

REVISION CHANGES

Dec 14, 2009	A	Release		Christian Rosu
Apr 16, 2010	B	Updated references & CS-11979 addition		Christian Rosu

	FLEXTRONICS LABORATORY MANAGEMENT SYSTEM	DOC # 705304-111
		REVISION # B
EMC LABORATORY 213 Harry Walker Parkway South NEWMARKET, ON, L3Y 8T3 Tel: 905-952-1242	IMMUNITY TO TRANSIENTS ON POWER LINES PULSE #1 TEST PROCEDURE	SUPERSEDE A
		RELEASE DATE 2010-04-16
		DOC TYPE WORK INSTR

END-USER FEEDBACK

☐ very satisfied
 ☐ satisfied
 ☐ neutral
 ☐ dissatisfied
 ☐ very dissatisfied

Please rate your overall satisfaction with this LMS document and input your suggestions or comments.
Your opinion is very important for us.

Survey Date

